



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Valley Residential Care Inc.	Provider Number	2379
Address	14106 E 3RD AVE ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA	Facility Type	Residential Care

On 07/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Repair of penetrations

Repair of penetrations. Where damaged, materials used to protect membrane- and through-penetrations shall be replaced or restored with materials or systems that meet or exceed the code requirements applicable at the time when the assembly was constructed, remodeled or altered.

Corrected.

Next inspection scheduled on or after: 08/31/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Brittany Ellis manager
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Valley Residential Care Inc.	Provider Number	2379
Address	14106 E 3RD AVE ,	Approval Status	Disapproved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

For your information.

2 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.

(IFC 603.6 2021)

Room 24 had 2 unapproved extension cords in use.

Removed at inspection.

3 Repair of penetrations

Repair of penetrations. Where damaged, materials used to protect membrane- and through-penetrations shall be replaced or restored with materials or systems that meet or exceed the code requirements applicable at the time when the assembly was constructed, remodeled or altered.

In the following locations there are wall penetrations:

1. Linen/Oxygen room
2. Back refrigerator room
3. Riser room

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Valley Residential Care Inc.	Provider Number	2379
Address	14106 E 3RD AVE ,	Approval Status	Disapproved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 07/04/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Brittany Ellis - Manager
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature

This document was prepared by Residential Care Services for the Locator website.