



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sound Vista Village Inc	Provider Number	2382
Address	6633 MCDONALD AVE ,	Approval Status	Approved
City, State, Zip	Gig Harbor, WA 98335	Facility Type	Residential Care

On 06/13/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------


1 Admin Complaint

COMPLAINT # 84029 Here's a complaint of sprinklers triggered by generator maintenance Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 84029 On 6/13/2023 a complaint investigation was conducted at Sound Vista Village located 6633 McDonald Ave, Gig Harbor, WA. Interviews were conducted with the Executive Director and front desk staff. Generator muffler was installed too close to a sprinkler head which activated the sprinkler system in the maintenance office. Generator repairs approved and muffler is being removed away from sprinkler head. Sprinkler head has been replaced and fire alarm system in normal status. There was no fire, the sprinkler system was activated, the building was evacuated per local fire department, there were no injuries and the fire department did respond.
---	--

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Tina Nott Executive Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature