



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Elma Home Care	Provider Number	2383
Address	901 YOUNG ,	Approval Status	Approved
City, State, Zip	Elma, WA	Facility Type	Residential Care

On 12/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Sara Jordan - Administrator
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Elma Home Care
Address 901 YOUNG ,
City, State, Zip Elma, WA

Provider Number 2383
Approval Status Disapproved
Facility Type Residential Care

On 10/01/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)


Findings during inspection were:

- Fire sprinkler fire department connection 5-year hydrostatic test needed.
- Facility failed to provide reports that quarterly inspections are being conducted.
- Facility had sprinkler heads that were loaded with debris, facility wide inspection shall be conducted.

Next inspection scheduled on or after: 11/01/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Sara Jordan - Administrator
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature