



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Stephen's Place

Provider Number 2414

Address 501 SE ELLSWORTH RD ,

Approval Status Approved


City, State, Zip Vancouver, WA

Facility Type Residential Care

On 02/11/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Heather Bartholomew, Executive Director
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Stephen's Place
Address 501 SE ELLSWORTH RD ,
City, State, Zip Vancouver, WA

Provider Number 2414
Approval Status Disapproved
Facility Type Residential Care

On 01/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Facility shall provide annual forward flow of fire sprinkler system

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.


(IFC 907.8 2021)

Facility fire alarm system found in trouble at time of inspection

Next inspection scheduled on or after: 02/07/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Heather Bartholomew, Executive Director
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Nicholas D. Wolden
Signature