



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Welcome Home (Oak Harbor Senior Memory Care)	Provider Number	2424
Address	235 6TH ,	Approval Status	Approved
City, State, Zip	Oak Harbor, WA 98277	Facility Type	Residential Care

On 09/12/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Sandra K Oldemeyer
Signature

Sandra K Oldemeyer LPN / DON
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Welcome Home (Oak Harbor Senior Memory Care) **Provider Number** 2424
Address 235 6TH , **Approval Status** Disapproved
City, State, Zip Oak Harbor, WA 98277 **Facility Type** Residential Care

On 08/07/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

The following violations were observed:

There was heat wrap and insulation hanging on the outside sprinkler piping near the south east exit.

2 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.12.5.2 2018)

The following violations were observed:

Facility is unable to provide an inventory list for the monthly single station smoke alarm testing.

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72.

IFC 907.8

The following violations were observed:

The kitchen suppression system was installed with four 450 degree fusible links with no evidence of a proper heat test in accordance manufactures instructions.

Next inspection scheduled on or after: 09/06/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Sandra K Oldemeyer
Signature

Sandra K Oldemeyer CPN / GODIK
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

[Signature]
Signature