Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Herons Key at Gig Harbor ALF	***Provider Number***	2425
Address	4340 Borgen BLVD NW,	***Approval Status***	Approved
City, State, Zip	Gig Harbor, WA 98332	***Facility Type***	Residential Care

On 05/15/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

1 Admin Complaint

Code Requirement	Statement of Violation
COMPLAINT # 177073 Here's a complaint of Fire Watch Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 177073 On May 15th, 2025 a complaint investigation was conducted at Heron's Key Assisted Living Facility located at 4340 Borgen Blvd, Gig Harbor, WA 98332. An interview was conducted with facility staff. Facility was under construction and fire alarm system was going to be on test mode for less than 4 hours but sprinkler company arrived and was going to put system in test mode for an additional 4 hours so facility decided to go on fire watch. Systems are in normal status and fire watch documentation was provided. There was no sign of a fire, the sprinkler system was not activated, there were no evacuations, there were no injuries and the fire department did not respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

George Smith, Director of Facilities
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature

Initials of Authorized Facility Representative:_____

This document was prepared by Residential Care Services for the Locator website.