



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mukilteo Memory Care
Address 4686 POINTES DR ,
City, State, Zip Mukilteo, WA 98275

Provider Number 2426
Approval Status Approved
Facility Type Residential Care

On 09/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Stephanie Wicell, Executive Director
Print Name and Title

Deputy State Fire Marshal Arthur Jesse Ward
2803 156TH AVE SE
Bellevue WA 98007
(425) 401-7735

Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mukilteo Memory Care

Provider Number 2426

Address 4686 POINTES DR ,

Approval Status Disapproved

City, State, Zip Mukilteo, WA 98275

Facility Type Residential Care

On 08/15/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2018)

Facility is unable to provide documentation that the annual fire wall inspection has been completed.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mukilteo Memory Care

Address 4686 POINTES DR ,

City, State, Zip Mukilteo, WA 98275

Provider Number 2426

Approval Status Disapproved

Facility Type Residential Care

On 08/15/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

2 Commercial Cooking Systems

The automatic fire-extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Preengineered automatic dry- and wet-chemical extinguishing systems shall be tested in accordance with UL 300 and listed and labeled for the intended application. Other types of automatic fire-extinguishing systems shall be listed and labeled for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, its listing and the manufacturer's installation instructions. Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire extinguishing system. Signage shall indicate appliances from left to right, be durable and the size, color, and lettering shall be approved. Automatic fire-extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12.
2. Automatic sprinkler systems, NFPA 13.
3. Foam-water sprinkler system or foam-water spray systems, NFPA 16.
4. Dry-chemical extinguishing systems, NFPA 17.
5. Wet-chemical extinguishing systems, NFPA 17A.

Exception: Factory-built commercial cooking recirculating systems that are tested in accordance with UL 710B and listed, labeled and installed in accordance with Section 304.1 of the International Mechanical Code.

(IFC 904.12 2015, 2018)

Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mukilteo Memory Care
Address 4686 POINTES DR ,
City, State, Zip Mukilteo, WA 98275

Provider Number 2426
Approval Status Disapproved
Facility Type Residential Care

On 08/15/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

3 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1031.10.1 2018)

Facility is unable to provide documentation for the monthly 30 second activation test for the emergency lights.

4 Fire/Emergency Plan

Fire emergency plan. All Group I, Group E, Group LC and Group R Occupancies shall develop and maintain a written fire emergency plan. The plan shall include the following: (1) Action to take by the person discovering a fire. (2) Method of sounding an alarm on the premises. (3) Actions to take for evacuation and assuring accountability of the occupants. (4) An evacuation floor plan identifying exits. (5) In Group R, Division 1 Occupancies and Group R, Division 3 Occupancies used as transient accommodations, a copy of the written evacuation plan shall be posted in each guest room.

(WAC 212-12-040)

Facility cannot provide a documented emergency plan in accord with WAC 212-12-040

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mukilteo Memory Care
Address 4686 POINTES DR ,
City, State, Zip Mukilteo, WA 98275

Provider Number 2426
Approval Status Disapproved
Facility Type Residential Care

On 08/15/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 09/14/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Civil
Signature

Stephanie Kiesel, Executive Director
Print Name and Title

Deputy State Fire Marshal Arthur Jesse Ward
2803 156TH AVE SE
Bellevue WA 98007
(425) 401-7735

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.