



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	High Point Village	Provider Number	2432
Address	1777 HIGHPOINT ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA 98022	Facility Type	Residential Care

On 06/08/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------


1 Admin Complaint

COMPLAINT # 82498 Here's a complaint of fire system in test mode for testing Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On June 06, 2023 DSFM Christian entered High Point Village to conduct a complaint inspection regarding the fire alarm system being put on test mode. The Maintenance Director stated that they were conducting their annual inspection on the alarm system and had heaters in one resident room due to bed bugs. The facility conducted a fire watch. No deficiencies at this time.
---	---

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Austin Zeober - Maintenance Director
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature