



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	High Point Village	Provider Number	2432
Address	1777 HIGHPOINT ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA 98022	Facility Type	Residential Care

On 01/17/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 114434

Here's a complaint of broken water pipe

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes

On January 17, 2024 DSFM Christian entered High Point Village is regards to complaint # 114434. The complaint was regarding a busted water pipe.

I spoke with the maintenance person who stated during the cold weather they notice the water not working in resident room M8. The facility called the plumber who discovered they had broken pipes. The sprinkler system is currently shut down. The facility is currently waiting for contractor to fix the pipes and restore the system. The facility is conducting a fire watch at this time.

When repairs have been made and the system is back up and running the facility will need to contact me and send over their fire watch forms.

No violations observed at this time.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Angie Howells
Signature

Angie Howells, Executive Director
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Cozetta
Signature