



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	High Point Village	Provider Number	2432
Address	1777 HIGHPOINT ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA 98022	Facility Type	Residential Care

On 07/30/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 139250

Here's a complaint of sprinkler system needing repairs

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? No

On July 30, 2024, DSFM Christian entered High Point Village located at 1777 Highpoint St, Enumclaw, Wa to investigate complaint ref # 139250. I interviewed the Maintenance director. The facility is currently installing sprinklers under a balcony / patio area on the second floor due to an annual inspection deficiency. On July 18, 2024 the facility took the sprinkler system offline to conduct repairs / install the sprinkler system. The facility conducted a fire watch during while the system was down.

No IFC violations observed at this time.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Joseph Chroniger Maintenance Director
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Signature