



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	High Point Village	Provider Number	2432
Address	1777 HIGHPOINT ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA 98022	Facility Type	Residential Care

On 09/30/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 147960

Here's a complaint of fire alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes

On September 30, 2024 DSFM Christian entered High Point Village located at 1777 Highpoint St, Enumclaw WA to investigate complaint ref # 147960. I interviewed the Facility Maintenance Director. Maintenance stated the facility had a resident who pulled the manual pull off the wall. This triggered the fire alarm to sound. The fire department came and reset the system. The pull station is up and running and the facility is working on enforcing it so that it can not be pulled off again. All systems worked properly.

No IFC violations observed.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Joseph Chroniger Maint. Director
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature