



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rose Pointe Assisted Living	Provider Number	2452
Address	13013 MISSION ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99216	Facility Type	Residential Care

On 01/14/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 160594

Here's a complaint of fire alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? No
4. If there were injuries / how many? Yes, one due to fall.
5. Did the fire department respond? Yes, for injured resident that fell due to being startled by fire alarm sound.

On January 14, 2025 a representative from the State Fire Marshals office conducted an inspection regarding a complaint of a fire alarm activation. An interview with staff [REDACTED] and Trudy Chamberlain was conducted.

A resident located in the ALF side had hot water running in the shower for an extended period of time and the steam caused the alarm to go off.

Staff called the 911 per their procedures because the fire alarm was going off. When fire department responded to the facility, they were diverted to the injured resident. Staff had cleared the fire alarm per their procedures and was on the phone with a followup call to the monitoring company to clear the alarm since there was no actual fire.

No code violations cited.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Trudy Chamberlain
Print Name and Title
Admin

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara R.
McMullen

Digitally signed by
Barbara R. McMullen
Date: 2025.01.22 13:24:53
-08'00'

Signature