



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aegis Living at Ravenna	Provider Number	2455
Address	8511 15TH AVE NE,	Approval Status	Disapproved
City, State, Zip	Seattle, WA	Facility Type	Residential Care

On 10/21/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected
--	-----------

2 Means of Egress Continuity

The path of egress travel along a means of egress shall not be interrupted by any building element other than a means of egress component as specified in this chapter. Obstructions shall not be placed in the minimum width or required capacity of a means of egress component except projections permitted by this chapter. The minimum width or required capacity of a means of egress system shall not be diminished along the path of egress travel. (IFC 1003.6 2021)	Corrected
--	-----------

3 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	-Facility is unable to provide documentation for the weekly inspections and Monthly 30 minute load testing. -The facility failed to provide documentation indicating a monthly generator battery test was being conducted in accord with NFPA 110 2021 edition section 8.3.6.1
--	--



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Aegis Living at Ravenna
Address 8511 15TH AVE NE,
City, State, Zip Seattle, WA

Provider Number 2455
Approval Status Disapproved
Facility Type Residential Care

On 10/21/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.

(WAC 212-12-044)

Facility cannot provide documentation for the completion of unannounced fire drills, one drill per shift, per quarter, in the previous 12 months.

Next inspection scheduled on or after: 11/27/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392

Signature