



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Avamere at Moses Lake
Address 8425 Aspi BLVD ,
City, State, Zip Moses Lake, WA 98837

Provider Number 2463
Approval Status Approved
Facility Type Residential Care

On 10/30/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 103822

Here's a complaint of power outage, generator malfunction

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 103822

On October 30th, 2023 a complaint investigation was conducted at Avamere at Moses Lake located at 8425 Aspi Boulevard NE, Moses Lake, WA 98837.

An interview was conducted with the Administrator and Maintenance. Generator had a small leak on the anti-freeze line which has been repaired and is in working order.

There were no signs of a fire, the sprinkler system was not activated, there were no evacuations, there were no injuries, and the fire department did not respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Not Available

Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature