



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Avamere at Moses Lake	Provider Number	2463
Address	8425 Aspi BLVD ,	Approval Status	Approved
City, State, Zip	Moses Lake, WA 98837	Facility Type	Residential Care

On 05/07/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------


1 Admin Complaint

COMPLAINT # 176560 Complaint of fire alarm activation. 1. The cause of the fire? Battery failure. Smoke only, no fire. 2. If the sprinklers were activated? No. 3. If there was an evacuation / how many were evacuated? facility 4. If there were injuries / how many? N/A 5. Did the fire department respond? Yes	On May 7, 2025 an off site complaint investigation was conducted at Avamere at Moses Lake located at 8425 Aspi Boulevard NE, Moses Lake, Washington. On April 23, 2025 at approximately 1222 hours the facility's fire alarm system activated. Moses Lake Fire Department. responded and reported the cause was due to a battery failure in a nursing paging system that was no longer in use. No violations were noted.
--	--

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Jodi Montoya ED
Print Name and Title

Deputy State Fire Marshal Barbara Maier
PO BOX 42642
Olympia WA 98504
(360) 596-3925
CDSFM Barbara A Maier

Digitally signed by CDSFM Barbara A Maier
DN: cn=CDSFM Barbara A Maier, o=Washington State Patrol, ou=Fire
Protection Bureau, email=barbara.maier@wsp.wa.gov, c=US
Date: 2025.05.08 07:41:04 -0700

Signature