



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Maplewood Gardens Assisted Living
Address 1100 N SUPERIOR ST ,
City, State, Zip Spokane, WA 99202

Provider Number 2470
Approval Status Approved
Facility Type Residential Care

On 03/27/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 120951

Here's a complaint of sprinkler burst.

Fire Sprinkler contractor was working on sprinkler system and wrong water zone was shut off causing sprinkler pipe to burst.

Pipe has been fixed and sprinkler system back on line. Email from Hiller 4/8/24.

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated?
None
4. If there were injuries / how many? None
5. Did the fire department respond? No

No violations.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Maplewood Gardens Assisted Living	Provider Number	2470
Address	1100 N SUPERIOR ST ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99202	Facility Type	Residential Care

On 03/27/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Andy Downing
Signature

Andy Downing Meiat.
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara K. McMullen
Signature

This document was prepared by Residential Care Services for the Locator website.