



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Columbia Landing of Issaquah	Provider Number	2471
Address	23845 ISSAQUAH FALL CITY RD ,	Approval Status	Approved
City, State, Zip	Issaquah, WA 98029	Facility Type	Residential Care

On 8/1/2023 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(360) 481-3933


Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care - Issaquah	Provider Number	2471
Address	23845 ISSAQUAH FALL CITY RD ,	Approval Status	Disapproved
City, State, Zip	Issaquah, WA 98029	Facility Type	Residential Care

On 7/18/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Record Keeping

Records shall be maintained of required emergency evacuation drills and include the following information:

1. Identity of the person conducting the drill.
2. Date and time of the drill.
3. Notification method used.
4. Employees on duty and participating.
5. Number of occupants evacuated.
6. Special conditions simulated.
7. Problems encountered.
8. Weather conditions when occupants were evacuated.
9. Time required to accomplish complete evacuation.

(IFC 0405.5 2018)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Facility cannot provide documentation for the completion of twelve planned and unannounced fire drills in the previous 12 months.

The following Drills are missing.

- 1st Shift - Quarter 3 and 4
- 2nd Shift - Quarter 1,3 and 4
- 3rd Shift - Quarter 1, 2 and 4

2 Power Supply

Relocatable power taps shall be directly connected to a permanently installed receptacle.

(IFC 604.4.2 2018)

At time of inspection the following was observed:

1. There was a power strip plugged into another power strip found in maintenance office

3 Extension Cords

Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.

(IFC 604.5 2018)

At time of inspection the following was observed:

1. extension cord found in use in Maintenance office

4 Unapproved conditions

Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.

(IFC 604.6, 2018)

At time of inspection the following was observed:

1. open junction box missing cover in West Nursing Office



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care - Issaquah	Provider Number	2471
Address	23845 ISSAQUAH FALL CITY RD ,	Approval Status	Disapproved
City, State, Zip	Issaquah, WA 98029	Facility Type	Residential Care

On 7/18/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
5 Cleaning	
Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 607.3.3.1 through 607.3.3.3. (IFC 607.3.3 2018)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. First semi-annual hood cleaning All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.
6 Owner's Responsibility	
The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space. (IFC 701.6 2018 WAC 51-54A)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Facility will need to identify and establish a schedule for inspection of Fire-Rated construction by 30 days of this inspection. 2. Annual inspection of fire-resistance-rated construction will need to be performed and completed by end of 2023. All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care - Issaquah	Provider Number	2471
Address	23845 ISSAQUAH FALL CITY RD ,	Approval Status	Disapproved
City, State, Zip	Issaquah, WA 98029	Facility Type	Residential Care

On 7/18/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

7 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. 5-Year internal pipe Testing (NFPA 25 14.2.1.1)
2. 3-Year Dry System Full flow trip test (NFPA 25 13.1.1.2)
3. Annual forward flow test (NFPA 25 13.7.2)
4. 5-years Backflow internal pipe (IFC 901.6)
5. 5-Year FDC Hydro testing (IFC 912.7)
6. first Quarter inspection

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Fieldstone Memory Care - Issaquah
Address 23845 ISSAQUAH FALL CITY RD ,
City, State, Zip Issaquah, WA 98029

Provider Number 2471
Approval Status Disapproved
Facility Type Residential Care

On 7/18/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

8 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of either the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational, that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Facility will need to identify and establish a schedule for inspection of Fire Doors by 30 days of this inspection.
2. Annual inspection of fire doors will need to be performed and completed by end of 2023.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care - Issaquah	Provider Number	2471
Address	23845 ISSAQUAH FALL CITY RD ,	Approval Status	Disapproved
City, State, Zip	Issaquah, WA 98029	Facility Type	Residential Care

On 7/18/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been performed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and integrity 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 8/17/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Mark Ainsworth, Maintenance
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(360) 481-3933

Signature

Jason E Van Gorkum