



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Gardens at Marysville, Independent Living & AL	Provider Number	2476
Address	9802 48th ,	Approval Status	Approved
City, State, Zip	Marysville, WA 98270	Facility Type	Residential Care

On 01/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 114470 Here's a complaint of broken water pipes Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 114470 At 1400 on 01/18/2024, DSFM Brown conducted a phone inspection for The Gardens At Marysville located at 9802 48th Dr Ne, Marysville, WA, 98270. An interview with the Facility Maintenance Director, to investigate complaint ref# 114470 was completed. At approximately 1545 on 01/13/24 there was a pipe rupture in entryway to the community. Main water was secured, once is was discovered that in was a sprinkler pipe the sprinkler system control valve was secured and the main water to the building was restored. Repairs have not been completed. Fire watch is being conducted, rounds every 15 minutes with a dedicated trained person. No injuries were report. No violations observed.
---	---

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Brandon G. Brown
Digitally signed by Brandon G. Brown
Date: 2024.01.18 14:39:57 -08'00'

Signature