



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Pine Ridge Alzheimer's Special Care Center	Provider Number	2513
Address	12009 E MISSION AVE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 12/20/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Open electrical terminations

Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.

(IFC 603.2.2, 2021)

Corrected.

2 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Completed/provided.

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

1. It appears that UL testing has been completed in 2018, please have UL documentation available at reinspection. Received.

2. NFPA 25 13.7.2. Testing fo backflow preventor shall be required. Completed/report provided.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Pine Ridge Alzheimer's Special Care Center	Provider Number	2513
Address	12009 E MISSION AVE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 12/20/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

4 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
 - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
 - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
 - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
 - 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.
 - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

Acknowledged.

5 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Provided.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Pine Ridge Alzheimer's Special Care Center	Provider Number	2513
Address	12009 E MISSION AVE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 12/20/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

6 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced. (IFC 915.6 2021 WAC)	Installed.
--	------------

7 Security

Compressed gas containers, cylinders, tanks and systems shall be secured against accidental dislodgement and against access by unauthorized personnel in accordance with Sections 5303.5.1 through 5303.5.3. (IFC 5303.5 2021)	Corrected.
---	------------

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Pine Ridge Alzheimer's Special Care Center	Provider Number	2513
Address	12009 E MISSION AVE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 12/20/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of either the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non-combustible threshold are secured, aligned and in working order with no visible signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close

Completed.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Pine Ridge Alzheimer's Special Care Center	Provider Number	2513
Address	12009 E MISSION AVE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 12/20/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

before the active lead
9. Latching hardware operates and secures the door when it is in the closed position
10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame
11. No field modification to the door assembly have been performed that void the label.
12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and integrity
13. Signage affixed to a door meets the requirements listed in 4.1.4

9 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year.
(1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions.
(2) A detailed written record of all fire drills shall be maintained and available for inspection.
(3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.

Completed.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Pine Ridge Alzheimer's Special Care Center	Provider Number	2513
Address	12009 E MISSION AVE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 12/20/2024 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 01/31/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Justin Randolph ESD
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature