




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Fairhaven	Provider Number	2525
Address	2600 OLD FAIRHAVEN PKWY ,	Approval Status	Approved
City, State, Zip	Bellingham, WA 98225	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

PETER P. DAY MAINTENANCE DIRECTOR
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Fairhaven	Provider Number	2525
Address	2600 OLD FAIRHAVEN PKWY ,	Approval Status	Disapproved
City, State, Zip	Bellingham, WA 98225	Facility Type	Residential Care

On 03/05/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Listing

603.5.1 Listing. Relocatable power taps shall be listed in accordance with UL 1363. Current taps shall be listed and labeled in accordance with UL 498A. (IFC 603.5.1, 2021)	There was multi-plug adapter that does not have over current protection in use in the nurses office
---	---

2 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	1. There was an extension cord utilized as permanent wiring in the Wellness Center. 2. There was an extension cord utilized as permanent wiring in the Living Room.
---	--

3 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	The mechanical room near room 21 does not have an automatic door closure.
--	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Fairhaven	Provider Number	2525
Address	2600 OLD FAIRHAVEN PKWY ,	Approval Status	Disapproved
City, State, Zip	Bellingham, WA 98225	Facility Type	Residential Care

On 03/05/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

1. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.

2. The hydraulic calculation placard is missing from the sprinkler system.

3. Facility unable to provide documentation of the UL test results from the sprinkler head testing.

Next inspection scheduled on or after: 04/04/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

PETER P. DAY MAINTENANCE DIRECTOR
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 794-7037


Signature

Initials of Authorized Facility Representative: _____