



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name Cypress Assisted Living Inc
Address 911 21ST ,
City, State, Zip Anacortes, WA 98221

Provider Number 2527
Approval Status Approved
Facility Type Residential Care

On 07/12/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Cypress Assisted Living Inc	Provider Number 2527
Address 911 21ST ,	Approval Status Disapproved
City, State, Zip Anacortes, WA 98221	Facility Type Residential Care

On 06/08/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Extension Cords

Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.

(IFC 604.5 2018)

The following violations were observed:

1. There was an extension cord utilized as permanent wiring in the Executive Directors office
2. There was an extension cord utilized as permanent wiring in room #304

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

The following violations were observed:

Facility is unable to provide documentation for the 5 year internal piping inspection.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Cypress Assisted Living Inc	Provider Number 2527
Address 911 21ST ,	Approval Status Disapproved
City, State, Zip Anacortes, WA 98221	Facility Type Residential Care

On 06/08/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
3 Securing Compressed Gas Containers, Cylinders and Tanks	
Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods: 1. Securing containers, cylinders and tanks to a fixed object with one or more restraints. 2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks. 3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress. 4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use. Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing. (IFC 5303.5.3 2018)	The following violations were observed: 1. Ten oxygen cylinders in the oxygen storeroom are not secured to prevent the cylinders from falling. 2. One oxygen cylinder in room #304 is not secured to prevent the cylinder from falling.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cypress Assisted Living Inc	Provider Number	2527
Address	911 21ST ,	Approval Status	Disapproved
City, State, Zip	Anacortes, WA 98221	Facility Type	Residential Care

On 06/08/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 07/08/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

Initials of Authorized Facility Representative: _____