



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Artesian Place	Provider Number	2542
Address	828 MCPHEE RD SW,	Approval Status	Approved
City, State, Zip	Olympia, WA 98502	Facility Type	Residential Care

On 02/18/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Artesian Place	Provider Number	2542
Address	828 MCPHEE RD SW,	Approval Status	Disapproved
City, State, Zip	Olympia, WA 98502	Facility Type	Residential Care

On 01/15/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 COVID - 19 Pandemic (ALFs)

Memorandum of record: Inspection request received 5/26/2021
Due to the state of emergency declaration of the COVID-19 pandemic event; Department of Social and Health Services (DSHS), halted on-site licensing renewals and activities. DSHS revoked the request per RCW 18.20.130, of the Washington State Fire Marshal Office (SFMO) to conduct renewal licensing inspections of licensed Assisted Living Facilities (ALFs) from April 1, 2020 to April 18, 2021.

2 Smoke Detector Sensitivity

Smoke detector sensitivity shall be checked within one year after installation and every alternate year thereafter. After the second calibration test, where sensitivity tests indicate that the detector has remained within its listed and marked sensitivity range (or 4-percent obscuration light grey smoke, if not marked), the length of time between calibration tests shall be permitted to be extended to a maximum of 5 years. Where the frequency is extended, records of detector-caused nuisance alarms and subsequent trends of these alarms shall be maintained. In zones or areas where nuisance alarms show any increase over the previous year, calibration tests shall be performed.

(IFC 907.8.3 2021)

Findings during the inspection were:

Sensitivity test is required for all smoke detectors.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Artesian Place	Provider Number	2542
Address	828 MCPHEE RD SW,	Approval Status	Disapproved
City, State, Zip	Olympia, WA 98502	Facility Type	Residential Care

On 01/15/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 02/15/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Pat White Maintenance
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature