



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900


|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Approved         |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 06/04/2024 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

  
Signature

  
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum  
2803 156 AVE SE  
Bellevue WA 98007  
(509) 406-7209

  
Signature

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



**Washington State Patrol**  
**Fire Protection Bureau**  
Phone: (360) 596-3900

|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 04/15/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

### 1 Ceiling Clearance

Storage shall be maintained 2 feet (610 mm) or more below the ceiling in nonsprinklered areas of buildings or not less than 18 inches (457 mm) below sprinkler head deflectors in sprinklered areas of buildings.

**Exceptions:**

1. The 2-foot (610 mm) ceiling clearance is not required for storage along walls in nonsprinklered areas of buildings.
2. The 18-inch (457 mm) ceiling clearance is not required for storage along walls in areas of buildings equipped with an automatic sprinkler system in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3.

(IFC 315.3.1 2021)

At time of inspection the following was observed:

1. kitchen dry storage has combustible materials near sprinkler
2. laundry room has combustible materials near sprinkler

### 2 Means of Egress - Storage in Buildings

Combustible materials shall not be stored in exits or enclosures for stairways and ramps. Combustible materials in the means of egress during construction, demolition, remodeling or alterations shall comply with Section 3311.3.

(IFC 315.3.2 2021)

At time of inspection the following was observed:

1. basement egress has storage in the path

### 3 Open electrical terminations

Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.

(IFC 603.2.2, 2021)

At time of inspection the following was observed:

1. 2nd floor in hallway by janitor room has an open junction

### 4 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code.

(IFC 603.5, 2021)

At time of inspection the following was observed:

1. 4th floor care manager room has a multi adapter
2. 2nd floor room 221 has a multi adapter with a extension cord plugged into it
3. 2nd floor room 221 has a extension cord in use

This document was prepared by Residential Care Services for the Locator website.



**Washington State Patrol**  
**Fire Protection Bureau**  
Phone: (360) 596-3900

|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 04/15/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**5 Inspection and Maintenance**

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

At time of inspection the following was observed:

1. kitchen has fire door propped open
2. room 209 door is propped open

**6 Door Operation**

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2021)

At time of inspection the following was observed:

1. 4th floor room 401 will not latch
2. 3rd floor double doors by 314 will not latch
3. 2nd floor double doors by nurses station will not latch
4. 2nd floor double doors in assisted living coordinator will not latch

**7 Testing and Maintenance**

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Annual report
2. 3-Year Dry System Full flow trip test (NFPA 25 13.1.1.2)
3. Annual Trip Test (NFPA 25 13.1.1.2)
4. Annual forward flow test (NFPA 25 13.7.2)
5. Quarterly inspections

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



**Washington State Patrol**  
**Fire Protection Bureau**  
Phone: (360) 596-3900

|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 04/15/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

**8 Extinguishing System Service**

|                                                                                                                                                                                                                                                                                                               |                                                                                                                                                                                                                                                                                                                             |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.<br><br>(IFC 904.13.5.2 2021) | The following deficiencies were cited as a result of this inspection:<br><br>At the time of inspection the following paperwork was not provided:<br><br>1. Second semi-annual service<br><br>All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected. |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**9 Inspection, Testing and Maintenance**

|                                                                                                                                                                                                                                                                      |                                                                                                                                                                                                                                                                                                                                                                                                                          |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.<br><br>(IFC 907.8 2021) | The following deficiencies were cited as a result of this inspection:<br><br>At the time of inspection the following paperwork was not provided:<br><br>1. Annual report<br>2. Sensitivity Testing (IFC 907.8.3)<br>3. Monthly single and multiple station alarms test (IFC 907.8)<br><br>All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected. |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 04/15/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

**10 Carbon Monoxide Detection - General**

Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the International Fire Code.

(IFC 0915.1 2021 WAC 51-54A)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Carbon Monoxide Alarms and Detectors will need to be tested, maintained and documented on am monthly schedule

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

At time of inspection the following was observed:

1. 4th floor housekeeping supply room needs CO detector
2. basement boiler room needs CO Detector

**11 Activation Test**

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1032.10.1 2021)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. 30-second monthly activation testing had not been performed and documented

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



**Washington State Patrol**  
**Fire Protection Bureau**  
Phone: (360) 596-3900

|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 04/15/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

**12 Power Test**

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.

(IFC 1031.10.2 2021)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Annual 90 minute power test had not been performed and documented

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

**13 Maintenance**

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Annual service report
2. Log of weekly inspections
3. Monthly 30-minute full load test
4. fuel test

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                   |                        |                  |
|-------------------------|-----------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Sunrise of Issaquah               | <b>Provider Number</b> | 2543             |
| <b>Address</b>          | 23599 SE Issaquah- Fall City RD , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Issaquah, WA 980299265            | <b>Facility Type</b>   | Residential Care |

On 04/15/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

**Next inspection scheduled on or after: 05/22/2024**

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum  
2803 156 AVE SE  
Bellevue WA 98007  
(509) 406-7209

Jason E Van Gorkum  
\_\_\_\_\_  
Signature

This document was prepared by Residential Care Services for the Locator website.