




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Longhouse-Bothell	Provider Number	2547
Address	16605 122ND PL NE,	Approval Status	Approved
City, State, Zip	Bothell, WA	Facility Type	Residential Care

On 11/3/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

MATTHEW LUND, OWNER
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392

Damon
Roberson
n

Digitally signed
by Damon
Roberson
Date: 2025.11.03
08:57:15 -08'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Longhouse-Bothell	Provider Number	2547
Address	16605 122ND PL NE,	Approval Status	Disapproved
City, State, Zip	Bothell, WA	Facility Type	Residential Care

On 10/23/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

The facility provided documentation for the annual forward flow test. The documentation also indicated that there is no hydraulic calculation plate. The facility will need to install the hydraulic calculation plate to verify that the minimum system demand flow rate was met during testing.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

Next inspection scheduled on or after: 11/24/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

MATTHEW LONG, OWNER
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392

Damon Roberson
Digitally signed by
Damon Roberson
Date: 2025.10.27
10:48:54 -07'00'

Signature