



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Tri-Cities Assisted Living	Provider Number 2549
Address 2000 22ND ,	Approval Status Approved
City, State, Zip Pasco, WA 99301	Facility Type Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 173924 Here's a complaint of power outage 1. The cause of the fire? No. 2. If the sprinklers were activated? No. 3. If there was an evacuation / how many were evacuated? None. 4. If there were injuries / how many? No 5. Did the fire department respond? No.	On April 9, 2025 I conducted a complaint inspection at Tri-Cities Assisted Living facility in Pasco, Washington. The complaint states that on April 1, 2025 there was a power outage affecting all resident on the second floor of the facility. During the inspection the Executive Director stated power outage only occurred on one wing of the second floor and initiated in resident apartment 208 and was limited to that apartment, the laundry room across apartment 208 and the bathrooms of other apartments in the same corridor. The Executive Director confirmed that power went out on April 1, 2025. Electrical contractors assessed the reason for the outage on April 2, 2025. Power was restored to all effected areas on April 3, 2025 after electrical contractors made repairs. Building's fire systems did not show signs of being affected due to the outage. Facility's procedures were followed and no code violations were observed.
--	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Tri-Cities Assisted Living	Provider Number	2549
Address	2000 22ND ,	Approval Status	Approved
City, State, Zip	Pasco, WA 99301	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Kiri Beveler RCC
Signature 4/10/25

Print Name and Title

Deputy State Fire Marshal Jessica Teobaldino-Mutton
143302 E Law Lane
Kennewick WA 99337
(425) 557-0362

J Teobaldino-Mutton
Signature