




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Puyallup	Provider Number	2561
Address	2121 S MERIDIAN ,	Approval Status	Approved
City, State, Zip	Puyallup, WA	Facility Type	Residential Care

On 8/5/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

MICK GERBER MAINTANANCE DIRECTOR
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Fieldstone Memory Care of Puyallup
Address 2121 S MERIDIAN ,
City, State, Zip Puyallup, WA 98371

Provider Number 2561
Approval Status Disapproved
Facility Type Residential Care

On 5/14/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Means of Egress - Storage in Buildings

Combustible materials shall not be stored in exits or enclosures for stairways and ramps. Combustible materials in the means of egress during construction, demolition, remodeling or alterations shall comply with Section 3311.3.

(IFC 315.3.2 2021)

Corrected

2 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

Corrected

3 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.

(IFC 703.1 2021)

Corrected

4 Inspection, Testing and Maintenance

Fire protection and life safety systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection and life safety systems and equipment shall be inspected, tested and maintained or removed in accordance with Section 901.8.

(IFC 901.6 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Fieldstone Memory Care of Puyallup
Address 2121 S MERIDIAN ,
City, State, Zip Puyallup, WA 98371

Provider Number 2561
Approval Status Disapproved
Facility Type Residential Care

On 5/14/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

5 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the reinspection were:

Unable to produce quarterly fire sprinkler inspection reports for Q1, Q2 and Q4 of 2024.

6 Group I

A manual fire alarm system that activates the occupant notification system in accordance with Section 907.5 shall be installed in Group I occupancies. An automatic smoke detection system that activates the occupant notification system in accordance with Section 907.5 shall be provided in accordance with Sections 907.2.6.1, 907.2.6.2 and 907.2.6.3.3.

Exceptions:

1. Manual fire alarm boxes in sleeping units of Group I-1 and I-2 occupancies shall not be required at exits if located at all care providers' control stations or other constantly attended staff locations, provided that such manual fire alarm boxes are visible and provided with ready access, and the distances of travel required in Section 907.4.2.1 are not exceeded.
2. Occupant notification systems are not required to be activated where private mode signaling installed in accordance with NFPA 72 is approved by the fire code official and staff evacuation responsibilities are included in the fire safety and evacuation plan required by Section 404.

(IFC 907.2.6 2021)

Corrected

7 Exit Discharge

Illumination shall be provided along the path of travel for the exit discharge from each exit to the public way.

Exception: Illumination shall not be required where the path of the exit discharge meets both of the following requirements:

1. The path of exit discharge is illuminated from the exit to a safe dispersal area complying with Section 1028.5.
2. A dispersal area shall be illuminated to a level not less than 1 footcandle (11 lux) at the walking surface.

(IFC 1008.2.3 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Puyallup	Provider Number	2561
Address	2121 S MERIDIAN ,	Approval Status	Disapproved
City, State, Zip	Puyallup, WA 98371	Facility Type	Residential Care

On 5/14/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 Reliability

Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.

(IFC 1032.2 2021)

Corrected

Next inspection scheduled on or after: 6/13/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Sandy Short
Signature

Sandra Short ED
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392

[Signature]
Signature