



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Silverdale	Provider Number	2583
Address	11313 CLEAR CREEK RD NW,	Approval Status	Approved
City, State, Zip	Silverdale, WA	Facility Type	Residential Care

On 10/14/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

NOT AVAILABLE
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

[Signature]
Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Silverdale	Provider Number	2583
Address	11313 CLEAR CREEK RD NW,	Approval Status	Disapproved
City, State, Zip	Silverdale, WA	Facility Type	Residential Care

On 06/30/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Frequency

Required emergency drills shall be held at the intervals specified in Table 405.3 or more frequently where necessary to familiarize all occupants with the drill procedure.
(IFC 405.2 2021)

Findings during the inspection were:

Facility failed to provide documentation showing fire drills are being conducted once per shift per quarter. Documentation shall be kept for the last 12 months.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.
(IFC 903.5 2021)

Findings during the inspection were:

Facility shall provide the following documentation for the fire sprinkler system;

- 3-year dry systems full flow trip test.
- Annual forward flow test for the backflow.

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.
(IFC 907.8 2021)

Findings during the inspection were:

Facility has two 1 hour fire rated sliding doors that are not being inspected by fire alarm company.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Silverdale	Provider Number	2583
Address	11313 CLEAR CREEK RD NW,	Approval Status	Disapproved
City, State, Zip	Silverdale, WA	Facility Type	Residential Care

On 06/30/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 08/01/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

GRIG PASE MAINT DIRECTOR
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature