



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Silverdale	Provider Number	2583
Address	11313 CLEAR CREEK RD NW,	Approval Status	Approved
City, State, Zip	Silverdale, WA	Facility Type	Residential Care

On 03/25/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 215450

Here's a complaint of Fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On 3/25/26 a complaint investigation was conducted at Fieldstone Memory Care of Silverdale located at 11313 Clear Creek Road NW, Silverdale, WA 98383.

An interview was conducted with facility staff. Washer/dryer combo started smoking due to a possible faulty dryer. Staff moved appliance outside and sprayed it with water with no further issues.

There was no fire, the sprinkler system and fire alarm did not activate, there were no injuries, there were no evaluations, and the fire department did not respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

ERIK PEASG MAINT. DIR.
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature