



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Aegis of Kirkland
Address 1002 Lake ST S,
City, State, Zip Kirkland, WA 98033

Provider Number 2586
Approval Status Approved
Facility Type Residential Care

On 6/13/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

JASON SCOTT M.D.
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(360) 481-3933


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Aegis of Kirkland	Provider Number 2586
Address 1002 Lake ST S,	Approval Status Disapproved
City, State, Zip Kirkland, WA 98033	Facility Type Residential Care

On 5/11/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Multiplug Adapters

Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with NFPA 70 shall be prohibited.

(IFC 604.4 2018)

The following deficiencies were cited as a result of this inspection:

Multi plug found in wellness office (resolved at time of inspection)

2 Power Supply

Relocatable power taps shall be directly connected to a permanently installed receptacle.

(IFC 604.4.2 2018)

The following deficiencies were cited as a result of this inspection:

Marketing room had power strips plugged into another power strip

3 Extension Cords

Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.

(IFC 604.5 2018)

The following deficiencies were cited as a result of this inspection:

Activity Office had a extension cord being used and running under a door.

4 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 607.3.3.1 through 607.3.3.3.

(IFC 607.3.3 2018)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. First semi-annual hood cleaning



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aegis of Kirkland	Provider Number	2586
Address	1002 Lake ST S,	Approval Status	Disapproved
City, State, Zip	Kirkland, WA 98033	Facility Type	Residential Care

On 5/11/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

5 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2018 WAC 51-54A)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Annual inspection of fire-resistance-rated construction (IFC 701.6) ✓

6 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.

(IFC 703.1 2018)

The following deficiencies were cited as a result of this inspection:

IDF room on the 3rd floor had multiple penetrations

7 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2018)

The following deficiencies were cited as a result of this inspection:

1. Fire rated doors will not latch by resident room 222



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aegis of Kirkland	Provider Number	2586
Address	1002 Lake ST S,	Approval Status	Disapproved
City, State, Zip	Kirkland, WA 98033	Facility Type	Residential Care

On 5/11/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

8 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2009, 2012, 2015, 2018)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Quarterly inspections
--	--

9 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.12.5.2 2018)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. First semi-annual servicing 2. Second semi-annual service 3. Annual replacement of fusible links/auto sprinkler heads (IFC 904.12.5.3)
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aegis of Kirkland	Provider Number	2586
Address	1002 Lake ST S,	Approval Status	Disapproved
City, State, Zip	Kirkland, WA 98033	Facility Type	Residential Care

On 5/11/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

10 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of wither the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Fire door annual inspection (IFC 705.2/NFPA 80 5.2)

During inspection:

1. Maintenance staff have been altering closing assembly from the original manufactory design
2. Resident door 214 would not self close
3. Resident room 217 would not self close



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aegis of Kirkland	Provider Number	2586
Address	1002 Lake ST S,	Approval Status	Disapproved
City, State, Zip	Kirkland, WA 98033	Facility Type	Residential Care

On 5/11/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been performed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 6/12/2023


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

JASON SCOTT MAINT DIR.
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(360) 481-3933


Signature