



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Messenger House Memory Care	Provider Number	
Address	10861 Manitou Park BLVD ,	Approval Status	Approved
City, State, Zip	Bainbridge Island, WA 98110	Facility Type	Residential Care

On 08/10/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 CRS Inspection Items

CRS 61156487 ALF Expansion Occupancy Type IBC: I-1, IBC: A-2, IBC: B Construction Type IBC: 5-A DOH Reviewer: Janet Smoot, 360-236-3970, janet.smoot@doh.wa.gov Facility Admin: Justin Younker, 509-426-2756, justin@cascadiadevelopment.com Facility Contact: Doug Ellison, 509-961-7942, doug@cascadiadevelopment.com Local AHJ: City of Bainbridge Island, Blake Holmes, 206-780-3715, bholmes@bainbridgewa.gov	On 7/27/2023 an initial construction review inspection was conducted by a representative of the Washington State Fire Marshal's Office to determine compliance with all applicable codes. Following are the deficiencies cited as a result of this inspection. All violations must be corrected upon re-inspection. * 8/10/23 UPDATE: Upon further review of the code, the facility is in compliance, and is approved.
--	--

2 Obstructed Locations

Automatic sprinklers shall be installed with regard to obstructions that will delay activation or obstruct the water distribution pattern and shall be in accordance with the applicable automatic sprinkler system standard that is being used. Automatic sprinklers shall be installed in or under covered kiosks, displays, booths, concession stands or equipment that exceeds 4 feet (1219 mm) in width. Not less than a 3-foot (914 mm) clearance shall be maintained between automatic sprinklers and the top of piles of combustible fibers. Exception: Kitchen equipment under exhaust hoods protected with a fire-extinguishing system in accordance with Section 904. (IFC 903.3.3 2018)	Approved.
---	-----------



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Messenger House Memory Care	Provider Number	
Address	10861 Manitou Park BLVD ,	Approval Status	Approved
City, State, Zip	Bainbridge Island, WA 98110	Facility Type	Residential Care


On 08/10/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.


Owner or Authorized Representative


Signature

Alena Gimlin, Executive Director

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

This document was prepared by Residential Care Services for the Locator website.