



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name	Memory Care at the Lodges	Provider Number	2600
Address	1530 CARPENTER ,	Approval Status	Disapproved
City, State, Zip	Lacey, WA 98503	Facility Type	Residential Care

On 03/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 168309 Here's a complaint of electrical hazards Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 168309 On February 27, 2025 a complaint investigation was conducted at Memory Care at the Lodges located at 1530 Carpenter Road, Lacey, WA 98503. An interview was conducted with facility staff. Paul Aube, an Investigator with DSHS accompanied during the investigation. Maintenance shop located in facility courtyard had multiple locations with exposed wires and the second floor of the shop has extension cords being used as permanent wiring. Other aspects of fire and life safety did not need to be cited. There was no sign of a fire, the sprinkler system was not activated, there were no evacuations, there were no injuries and the fire department did not respond. The following violations shall be corrected.
--	---

2 Open electrical terminations

Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes. (IFC 603.2.2, 2021)	Findings during the investigation were: Maintenance shop has multiple locations with exposed wires and any electrical hazards shall be abated.
---	--

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	Findings during the investigation were: 2nd floor of maintenance shop has extension cords being used as permanent wiring. Extension cords shall not be a substitute for permanent wiring.
---	---



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Memory Care at the Lodges	Provider Number	2600
Address	1530 CARPENTER ,	Approval Status	Disapproved
City, State, Zip	Lacey, WA 98503	Facility Type	Residential Care

On 03/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 04/04/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Rebecca Kinsley, Executive Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0087


Signature

Initials of Authorized Facility Representative: _____



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Memory Care at the Lodges	Provider Number	2600
Address	1530 CARPENTER ,	Approval Status	Approved
City, State, Zip	Lacey, WA 98503	Facility Type	Residential Care

On 03/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Rebecca Kinsley, Executive Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.