



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Park Gardens	Provider Number	2605
Address	4347 S UNION AVE ,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA	Facility Type	Residential Care

On 7/29/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	Findings during the reinspection were: 1) Corridor Fire Door 4- broken latch
--	---


2 Testing and Maintenance


Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected
--	-----------

Next inspection scheduled on or after: 8/28/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

 **EVS Director**
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392


Signature

Initials of Authorized Facility Representative: _____



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Park Gardens	Provider Number	2605
Address	4347 S UNION AVE ,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA 98409	Facility Type	Residential Care

On 5/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3. (IFC 606.3.3 2021)	Corrected
---	-----------

2 Maintaining Protection

Materials, systems and devices used to repair or protect breaches and openings in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained in accordance with Sections 703 through 707. (IFC 701.5 2018)	Corrected
---	-----------

3 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space. (IFC 701.6 2021)	Corrected
--	-----------

MZ

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Park Gardens	Provider Number	2605
Address	4347 S UNION AVE ,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA 98409	Facility Type	Residential Care

On 5/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Corrected
--	-----------

5 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	Findings during the reinspection were: 1) Corridor Fire Door 4- broken latch 2) Corridor Fire Door 2- failed to self close and latch during test 3) Room 306 A/B- failed to self close and latch during test
--	---

6 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	Corrected
---	-----------

ML



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Park Gardens	Provider Number	2605
Address	4347 S UNION AVE ,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA 98409	Facility Type	Residential Care

On 5/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

7 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Findings during the reinspection were: No documentation was provided for the most recent annual forward flow test, as required. During the inspection, Christopher Pace with Patriot Fire was observed on-site initiating a forward flow test. Documentation verifying completion of the test, including results and compliance with NFPA 25 requirements, must be submitted upon completion.
--	---

8 Testing

Testing shall be performed in accordance with the schedules in NFPA 72 or more frequently where required by the fire code official. Records of testing shall be maintained. Exception: Devices or equipment that are inaccessible because of safety considerations shall be tested during scheduled shutdowns where approved by the fire code official, but not less than every 18 months. (IFC 907.8.2 2021)	Corrected
---	-----------

9 Smoke Detector Sensitivity

Smoke detector sensitivity shall be checked within one year after installation and every alternate year thereafter. After the second calibration test, where sensitivity tests indicate that the detector has remained within its listed and marked sensitivity range (or 4-percent obscuration light grey smoke, if not marked), the length of time between calibration tests shall be permitted to be extended to a maximum of 5 years. Where the frequency is extended, records of detector-caused nuisance alarms and subsequent trends of these alarms shall be maintained. In zones or areas where nuisance alarms show any increase over the previous year, calibration tests shall be performed. (IFC 907.8.3 2021)	Corrected
--	-----------

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Cascade Park Gardens	Provider Number 2605
Address 4347 S UNION AVE ,	Approval Status Disapproved
City, State, Zip Tacoma, WA 98409	Facility Type Residential Care

On 5/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

10 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced.

(IFC 915.6 2021 WAC)

Corrected

11 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1032.10.1 2021)

Corrected

12 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.

(IFC 1031.10.2 2021)

Corrected

13 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year.

(1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions.

(2) A detailed written record of all fire drills shall be maintained and available for inspection.

(3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.

Corrected

ML



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Park Gardens	Provider Number	2605
Address	4347 S UNION AVE ,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA 98409	Facility Type	Residential Care

On 5/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 6/12/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Micah Lakin EVS Director
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392


Signature

This document was prepared by Residential Care Services for the Locator website.