



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Centralia Point Assisted Living and Memory Care	Provider Number	2609
Address	2010 COOKS HILL RD ,	Approval Status	Disapproved
City, State, Zip	Centralia, WA	Facility Type	Residential Care

On 11/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80.
Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105.
Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2018)

Fire doors throughout found out of compliance. Fire door inspection report provided identifies fire door out of compliance.


Maintenance director states that door repairs have been made, however, during a spot check he observed doors still out of compliance


Original citation was issued on 01/03/2024

Next inspection scheduled on or after: 12/25/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature
Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 857-0966


Print Name and Title
Centralia Point - Executive Director

Signature