



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sullivan Park Assisted Living Community	Provider Number	001612
Address	421 S ADAMS RD ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 09/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 140352

Here's a complaint of fire in cigarette receptacle

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? cigarettes
2. If the sprinklers were activated? no outside
3. If there was an evacuation / how many were evacuated? no
4. If there were injuries / how many? none
5. Did the fire department respond? no

Complaint ref # 140352

At 1100 on September 18, 2024, a representative from the State Fire Marshals Office investigated a complaint regarding cigarette receptacle fire and interviewed the Maintenance Supervisor.

Facility was unable to identify who may have caused smoldering cigarettes in and around cigarette receptable. Staff immediately drowned the smoldering with water.

Facility has removed/replaced cigarette containers as their plan of correction.

No violations cited.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Signature