



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	South Pointe Assisted Living	Provider Number	2610
Address	10330 4TH AVE W,	Approval Status	Approved
City, State, Zip	Everett, WA	Facility Type	Residential Care

On 02/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 212166 Here's a complaint of Structure Fire Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 212116 At 1445 on 02/18/2026, DSFM Brown conducted complaint inspection for South Pointe Assisted Living located at 10330 4th Ave W, Everett, WA 98204 to investigate complaint ref # 212116. I interviewed the Facility Executive Director. On 02/09/2025, at approximately 2350 the fire alarm was activated. Staff discovered smoke in the east corridor. The facility was evacuated in approximately 7 minutes. The Fire department did respond and found the smoke was coming from the HVAC unit in the attic space. Power was secured and the fire was extinguished. The fire department did cut 2 holes in the ceiling, which have already been repaired, and 2 holes in the roof that are temporarily covered. The west side of the facility was checked and cleared which allow the resident to re-enter that portion of the building. The installed sprinkler did not activate. No injuries were report. No violations observed.
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	South Pointe Assisted Living	Provider Number	2610
Address	10330 4TH AVE W,	Approval Status	Approved
City, State, Zip	Everett, WA	Facility Type	Residential Care

On 02/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Brandon Brown

Digitally signed by Brandon Brown
Date: 2026.02.18 17:32:23 -08'00'

Signature

This document was prepared by Residential Care Services for the Locator website.