



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name Brighton Court
Address 1308 N VERCLER RD ,
City, State, Zip Spokane, WA 99216

Provider Number 000841
Approval Status Approved
Facility Type Residential Care

On 06/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 129328

Here's a complaint of fire exit locked

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated?
N/A
4. If there were injuries / how many? N/A
5. Did the fire department respond? N/A

At 10:15 AM on 6/28/24, DSFM Barbara McMullen entered to investigate complaint ref # 129328. I interviewed the Executive Director.


The chain and lock have been removed from the gate and a key pad has been installed, codes for key pad has been posted.

No violations cited.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Bethany King Administrator
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature