



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Vista Manor	Provider Number	2377
Address	700 SE BRACE ST ,	Approval Status	Approved
City, State, Zip	Wilbur, WA 99185	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

For your information.

2 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code.

(IFC 603.5, 2021)

Room 2 had multiplug adapter in use. Removed at inspection.

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.

(IFC 603.6 2021)

Room 7 had 2 unapproved extension cords in use.
Removed at inspection.

4 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1032.10.1 2021)

Facility is unable to provide documentation for the monthly 30 second activation test for the emergency lights for the month of May 2025.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Vista Manor	Provider Number	2377
Address	700 SE BRACE ST ,	Approval Status	Approved
City, State, Zip	Wilbur, WA 99185	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 08/31/2026


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Seannie M Aungst Manager
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature

This document was prepared by Residential Care Services for the Locator website.