



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Parkside Retirement Community

Provider Number 2550

Address 2902 I ST NE,

Approval Status Approved

City, State, Zip Auburn, WA 98002

Facility Type Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 178857

Here's a complaint of Fire doors

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? No

On June 03, 2025, CDSFM Christian entered Parkside Retirement Community located at 2902 I St. NE, Auburn WA 98002 to investigate complaint ref # 178857. The complaint stated there were fire doors at the end of the hall being held open with rocks. I interview the Facility Maintenance Director and Executive Director. The E.D stated it was one person inparticular who places rocks next to the doors. The facility had conducted audits since and remove rocks as found. I completed a walkthrough and all doors were shut properly.

No IFC violations observed

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Signature

JOSE LUIS NAVARRO
MAINTENANCE