



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Fieldstone Orchard West Assisted Living
Address 4130 ENGLEWOOD AVE ,
City, State, Zip Yakima, WA 989082675

Provider Number 2648
Approval Status Approved
Facility Type Residential Care

On 04/10/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Contents

Fire safety, evacuation and lockdown plan contents shall be in accordance with Sections 404.2.1 through 404.2.3.2.

(IFC 404.2 2021)

Corrected.

2 Equipment Access

Approved access shall be provided and maintained for all fire protection system equipment to permit immediate safe operation and maintenance of such equipment. Storage, trash and other materials or objects shall not be placed or kept in such a manner that would prevent such equipment from being readily accessible..

(IFC 509.2, 2021)

Corrected.

3 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code.

(IFC 603.5, 2021)

Corrected.

4 Installation

Relocatable power tap cords shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to environmental or physical damage.

(IFC 603.5.3, 2021)

Corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Fieldstone Orchard West Assisted Living	Provider Number	2648
Address	4130 ENGLEWOOD AVE ,	Approval Status	Approved
City, State, Zip	Yakima, WA 989082675	Facility Type	Residential Care

On 04/10/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 02/28/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

 maintenance
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by Andrea
Ely
Date: 2025.04.10 00:32:53
-07'00'

Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Orchard West Assisted Living	Provider Number	2648
Address	4130 ENGLEWOOD AVE ,	Approval Status	Disapproved
City, State, Zip	Yakima, WA 989082675	Facility Type	Residential Care

On 03/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Contents

Fire safety, evacuation and lockdown plan contents shall be in accordance with Sections 404.2.1 through 404.2.3.2. (IFC 404.2 2021)	The following violation was observed: The facility failed to provide documentation of fire drills for the Day and Noc shifts for the first quarter; drills for March/2024 to December/2024 were provided.
--	--

2 Equipment Access

Approved access shall be provided and maintained for all fire protection system equipment to permit immediate safe operation and maintenance of such equipment. Storage, trash and other materials or objects shall not be placed or kept in such a manner that would prevent such equipment from being readily accessible.. (IFC 509.2, 2021)	The following violation was observed: In the Janitors/Electrical Room on the 1st Floor the FACP Communicator box was obstructed by combustible storage. (corrected)
---	--

3 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	The following violation was observed: In Room 109 there was an unfused 3-unit multi-plug adapter in use in the bathroom. (corrected)
--	---

4 Installation

Relocatable power tap cords shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to environmental or physical damage. (IFC 603.5.3, 2021)	The following violation was observed: In Room 201 there was a lift-assist bed installed and the cord was running through the bedroom door to the living room.
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Fieldstone Orchard West Assisted Living	Provider Number	2648
Address	4130 ENGLEWOOD AVE ,	Approval Status	Disapproved
City, State, Zip	Yakima, WA 989082675	Facility Type	Residential Care

On 03/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 04/10/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Andrew Bottino Campus
Maintenance Director
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Signature

Initials of Authorized Facility Representative: _____