



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Orchardwest	Provider Number	2648
Address	4130 ENGLEWOOD AVE ,	Approval Status	Approved
City, State, Zip	Yakima, WA 989082675	Facility Type	Residential Care

On 02/25/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following violation was observed:

-The facility failed to provide documentation of the semi-annual fire alarm system inspection, testing, and maintenance within the past twelve months. (Corrected)

Next inspection scheduled on or after: 02/28/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by
Andrea Ely
Date: 2026.02.25
01:12:30 -08'00'

Signature