



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Maple Glen Assisted Living	Provider Number 2655
Address 1700 N 13TH LOOP RD ,	Approval Status Approved
City, State, Zip Shelton, WA 98584	Facility Type Residential Care

On 02/05/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 113378

Here's a complaint of kitchen fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 113378

On February 5th, 2024 a complaint investigation was conducted at Maple Glen Assisted Living located at 1700 North 13th Loop Road, Shelton, WA 98584.

An interview was conducted with facility staff. Fire occurred in the kitchen right below the flat top due to grease build up where a cracked had formed. Staff pulled the fire alarm and responded with a fire extinguisher that extinguished the fire. Facility was evacuated and fire department allowed staff and residents to return. Due to nature of fire, kitchen suppression system did not activate.

There was a fire, the suppression or sprinkler system did not activate, the facility was evacuated, there were no injuries and the fire department did respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Jaime A. Hans
Signature

Jaime Hans, Executive Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

RhM
Signature