



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Buena Vista Inc	Provider Number	2672
Address	151 BUENA VISTA DR ,	Approval Status	Approved
City, State, Zip	Colville, WA	Facility Type	Residential Care

On 11/12/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.


(IFC 1203.4 2021)

Completed, report from DE Squared dated 10/29/25 received.

Next inspection scheduled on or after: 01/31/2027


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

TYSON LOU, ADMINISTRATOR
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Buena Vista Inc	Provider Number	2672
Address	151 BUENA VISTA DR ,	Approval Status	Disapproved
City, State, Zip	Colville, WA	Facility Type	Residential Care

On 10/31/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.
---	-----------------------

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	1. Facility is unable to provide documentation for the 3 year dry system full flow trip test. Scheduled with Western States for their annual on 3/20/25 contract provided, report to be provided once completed. Report received.
--	---

3 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	The following violations were observed: Facility is unable to provide documentation for the annual servicing of the emergency generator that was completed by DE Squared on 10/29/25. Report to be provided.
--	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Buena Vista Inc	Provider Number	2672
Address	151 BUENA VISTA DR ,	Approval Status	Disapproved
City, State, Zip	Colville, WA	Facility Type	Residential Care

On 10/31/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 11/30/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

TYSON LUU, ADMINISTRATOR
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Signature