



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	6 Stars Healthcare LLC	Provider Number	2681
Address	10816 18TH AVE E,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA	Facility Type	Residential Care

On 11/05/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Abatement of Electrical Hazards

Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated.. (IFC 603.2 2021)	2nd floor entry hallway has electrical boxes above the room doors with exposed wires.
--	---

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Facility failed to provide the following documentation for the fire sprinkler system; - 3-year dry system full flow trip test.
--	---

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Facility is unable to provide documentation for the semi-annual fire alarm system inspection and battery testing. The Fire alarm is in trouble, it is showing an account 2 trouble. This deficiency shall be corrected.
--	--

Next inspection scheduled on or after: 12/05/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Orlando Pitt - manager
Print Name and Title

Deputy State Fire Marshal Arthur Jesse Ward
2502 112 ST E
Tacoma WA 984455104
(425) 401-7735


Signature