




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Olympia	Provider Number	2687
Address	710 7TH AVE SW, BLD 1	Approval Status	Approved
City, State, Zip	Olympia, WA 98502	Facility Type	Residential Care

On 02/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature 


Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Olympia	Provider Number	2687
Address	710 7TH AVE SW, BLD 1	Approval Status	Disapproved
City, State, Zip	Olympia, WA 98502	Facility Type	Residential Care

On 12/02/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Findings during inspection were: Failed to provide annual inspection report for fire alarm system. Fire alarm is yellow tagged due to bad pull station in kitchen and needing new batteries.
--	--

2 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods: 1. Securing containers, cylinders and tanks to a fixed object with one or more restraints. 2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks. 3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress. 4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use. Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing. (IFC 5303.5.3 2021)	Findings during inspection were: Unsecured oxygen tanks in oxygen room.
--	--



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone Memory Care of Olympia	Provider Number	2687
Address	710 7TH AVE SW, BLD 1	Approval Status	Disapproved
City, State, Zip	Olympia, WA 98502	Facility Type	Residential Care

On 12/02/2024 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 01/05/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Shannon Kelly Campus Manager Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Raul Murcia Digitally signed by Raul Murcia
Date: 2024.12.05 12:22:17 -08'00'

Signature