



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name East Wenatchee Senior Living

Address 589 HIGHLINE DR , Ofc

City, State, Zip Wenatchee, WA 98802

Provider Number 2705

Approval Status Approved

Facility Type Residential Care

On 9/16/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 143481

Here's a complaint of fire alarm, system malfunction

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On Saturday, August 17, 2024 at East Wenatchee Senior Living located at 589 Highline Drive, Wenatchee, Washington, the fire alarm system was activated at approximately at 2200 hours due to a false alarm. The fire department responded on site and was able to deactivate the audible alarm to the facility, but was unable to return the system back to normal status. The facility contacted the fire alarm service company, which was able to respond and complete the repairs on August 19, 2024 to reset the system at 0945 hours.

The facility conducted a fire watch immediately after the fire alarm system was unable to be reset on August 17, 2024. No residents were harmed or injured, no additional building systems were affected, and fire watch documentation was submitted to our office by email on August 18, 2024 after the fire watch was concluded and the fire alarm system was set to normal status.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Signature

Print Name and Title

Jennifer Marcuson, Executive Director

Initials of Authorized Facility Representative: