



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	White River Assisted Living	Provider Number	2153
Address	2229 JENSEN ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA 98022	Facility Type	Residential Care

On 04/24/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 176215

Here's a complaint of sprinkler system

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes


On April 24, 2025, DSFM Christian entered White River Assisted Living located at 2229 Jensen St. Enumclaw WA, to investigate complaint ref # 176215 . I interviewed the Executive Director in - training. He stated TKE Elevator Technician was working in the ceiling shaft and mistakenly cut the water line to the East portion of the Community where residents reside. Water was shut off to this portion of the community, to minimize flood. No resident apartments were damaged. The water was off for about 4 hours. The facility was on fire watch every 30 minutes until the repair had been completed and fire panel reset. Fire Department arrived due to the fire alarm panel going off. The facility contacted me prior to receiving complaint and updated me and also sent me the fire watch information.

No IFC violations observed.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Michael Weitemann Executive Director in Training
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature