




Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | White River Assisted Living | <b>Provider Number</b> | 2713             |
| <b>Address</b>          | 2229 JENSEN ST,             | <b>Approval Status</b> | Approved         |
| <b>City, State, Zip</b> | Enumclaw, WA                | <b>Facility Type</b>   | Residential Care |

On 08/21/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

**All violations noted during previous related inspection(s) have been corrected.**

Owner or Owner's Representative

  
Signature

Michael Weitenman E.D.T.  
Print Name and Title

Deputy State Fire Marshal Cozetta Christian  
2502 112TH E  
Tacoma WA 984455104  
(360) 584-5796

  
Signature

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

**Business Name** White River Assisted Living  
**Address** 2229 JENSEN ST ,  
**City, State, Zip** Enumclaw, WA 98022

**Provider Number** 2153  
**Approval Status** Disapproved  
**Facility Type** Residential Care

On 8/19/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**1 Admin Complaint**

COMPLAINT # 189610

Here's a complaint of Fire Alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated? N/A
4. If there were injuries / how many? N/A
5. Did the fire department respond? No

On 08/19/2025 CDSFM Christian and DSFM Harlan entered White River Assisted Living for complaint # 189610 in regards to trouble on the fire alarm panel. During the investigation we spoke with the Executive Director and Maintenance Director. The fire alarm went into trouble status on 08/01/25. After multiple services the fire alarm panel was corrected on 08/05/25. They think it was the elevator but they were not sure. During our investigation we found that the main fire alarm panel was not in trouble but the communication radio network was causing the alarm company to notified the facility it was in trouble.

The facility started fire watch immediately but did it in 30 min increments. The policy for fire watch during fire alarm issues is 15 min increments. Do to current trouble we have requested the facility immediately go back into fire watch per their policy. The facility will have to prove that fire alarm system is operating properly to be removed from fire watch.

**2 Systems Out of Service**

Where a required fire protection system is out of service, the fire department and the fire code official shall be notified immediately and, where required by the fire code official, the building shall either be evacuated or an approved fire watch shall be provided for all occupants left unprotected by the shut down until the fire protection system has been returned to service.

Where utilized, fire watches shall be provided with at least one approved means for notification of the fire department and their only duty shall be to perform constant patrols of the protected premises and keep watch for fires.

Exception: Facilities with an approved notification and impairment management program. The notification and impairment program for water-based fire protection systems shall comply with NFPA 25.

(IFC 901.7 2021)

The following violation was observed:

During documentation review it was noticed that they were during 30 min intervals and not 15 required by policy.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                                                  |                                       |
|--------------------------------------------------|---------------------------------------|
| <b>Business Name</b> White River Assisted Living | <b>Provider Number</b> 2153           |
| <b>Address</b> 2229 JENSEN ST ,                  | <b>Approval Status</b> Disapproved    |
| <b>City, State, Zip</b> Enumclaw, WA 98022       | <b>Facility Type</b> Residential Care |

On 8/19/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

**3 Inspection, Testing and Maintenance**

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following violation was observed:

The fire alarm panel network is still in trouble status and may not be communicating with fire alarm panel.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

Next inspection scheduled on or after: 9/18/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

  
Signature

Michael Wittenmann EDIT  
Print Name and Title

Deputy State Fire Marshal Alan Harlan  
2803 156TH AVE SE  
Bellevue WA 98007  
(425) 495-7121

  
Signature