



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	White River Assisted Living	Provider Number	2713
Address	2229 JENSEN ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA	Facility Type	Residential Care

On 04/13/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 219910

Here's a complaint of compressor

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

ON 4/13/2026, DSFM Van Gorkum entered Assisted Living on Jensen located at 2229 JENSEN ST, ENUMCLAW, WA, 98022 investigate complaint ref # 219910.

What happened:)n 4/9/2026 at 4:00 pm No client involved, fire safety watch. this is involving our fire suppression, air compressor is low on air and we are on 30-minute fire watches until it is repaired. Fire suppression system, air compressor has low air. Therefore, fire department came out, recommended that we go on 30-minute fire watches, exterior of the building only is affected in the dry area, not residential apartments. ETA of repairs will be completed sometime tomorrow morning. Vendor has been called and we are attempting to locate uh new part that is required for system. Vendor has been called to come and repair the air compressor of the fire suppression. We believe it to be a faulty switch. They will be out tomorrow to repair.

Follow-up: Reporter states the facility is still on fire watch. Reporter states there is one staff delegated for fire watch, no other tasks. Reporter states repairs are currently being done, estimated finish time is around 12PM on 04/10/2026.

On 4/13/2026 a DSFM representative of the Washington State Patrol, Fire Protection Bureau to came to the facility to determine compliance with all applicable codes. Facility was able to show fire watch paperwork and show that the system is in normal statis. Local fire department removed the fire watch.

No IFC violations observed during this inspection.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	White River Assisted Living	Provider Number	2713
Address	2229 JENSEN ST ,	Approval Status	Approved
City, State, Zip	Enumclaw, WA	Facility Type	Residential Care

On 04/13/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement


Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2502 112 ST E
Tacoma WA 984455104
(509) 406-7209


Signature

This document was prepared by Residential Care Services for the Locator website.