



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Blossom Creek Senior Alzheimer Comm	Provider Number	2721
Address	1740 MADISON ST ,	Approval Status	Approved
City, State, Zip	Wenatchee, WA 98801	Facility Type	Residential Care

On 04/01/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Listing

603.5.1 Listing. Relocatable power taps shall be listed in accordance with UL 1363. Current taps shall be listed and labeled in accordance with UL 498A. (IFC 0603.5.1, 2021)	Corrected.
--	------------

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected.
--	------------

3 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times. (IFC 1013.5 2021)	Corrected.
--	------------

4 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Corrected.
--	------------

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Blossom Creek Senior Alzheimer Comm	Provider Number	2721
Address	1740 MADISON ST ,	Approval Status	Approved
City, State, Zip	Wenatchee, WA 98801	Facility Type	Residential Care

On 04/01/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 02/28/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Sam Mead
Signature

Sam Mead - Maint. Director
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by Andrea Ely
Date: 2025.04.01 19:38:21
-07'00'

Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Blossom Creek Senior Alzheimer Comm	Provider Number	2721
Address	1740 MADISON ST ,	Approval Status	Disapproved
City, State, Zip	Wenatchee, WA 98801	Facility Type	Residential Care

On 02/24/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Listing

603.5.1 Listing. Relocatable power taps shall be listed in accordance with UL 1363. Current taps shall be listed and labeled in accordance with UL 498A.

(IFC 0603.5.1, 2021)

1. Multi- Plug adapter that does not have over current protection located in the main laundry room.

2. Multi- Plug adapter that does not have over current protection located in the medical room.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Walk-in type cooler and freezer with automatic defrost has ordinary temperature heads installed.

3 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times.

(IFC 1013.5 2021)

Installed Emergency Exit Sign near 107A does not have a secondary power source to ensure continued illumination in case of primary power loss.

4 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

Emergency task lighting for the generator transfer room did not activate during testing.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Blossom Creek Senior Alzheimer Comm	Provider Number	2721
Address	1740 MADISON ST ,	Approval Status	Disapproved
City, State, Zip	Wenatchee, WA 98801	Facility Type	Residential Care


On 02/24/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 03/26/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Sam Mead - Maint. Director
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

This document was prepared by Residential Care Services for the Locator website.