



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Village Concepts of Auburn	Provider Number	2736
Address	2901 I ST NE,	Approval Status	Approved
City, State, Zip	Auburn, WA	Facility Type	Residential Care

On 02/25/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 213421

Here's a complaint of Sprinkler.

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? No

On February 25, 2025, CDSFM Christian entered Village Concepts of Auburn located at 2901 I St NE, Auburn, WA 98002 to investigate complaint ref # 213421.

On February 18, 2026 a contractor came to the facility to repair a sprinkler that was cited by the Fire Marshal. The contractor had to cut the pipe and glue it. The cure time was roughly 24 hours. The facility started a fire watch until the glue dried ending it on February 19, 2026. The sprinkler head is fixed and system is up and running.

No violations found at this time.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Sherlyn Bessette, ED
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
106 11th AVE SW
Olympia WA 98501
(360) 584-5796

Signature